



230008349512



中国认可
国际互认
检测
TESTING
CNAS L0681

CHPTL

CERTIFICATE OF TESTS

No : CTQC/B-23. 0111

Entrusted by: Qingdao Cahors Electrical Equipment Co., Ltd.

Manufacturer: Qingdao Cahors Electrical Equipment Co., Ltd.

Test object name: Three-phase oil-immersed distribution transformer

Test object type: 2000kVA 11.3/0.39kV

Serial No: 287230009C

Test items: Routine tests, type tests, measurement of zero-sequence impedance on three-phase transformers, measurement of the harmonics of the no-load current, short-circuit withstand test, induced voltage test with partial discharge measurement(IVPD).

Standards: IEC60076-1:2011, IEC60076-2:2011, IEC60076-3:2013, IEC60076-5:2006, technical contract.

Results: The test results of routine tests, type tests, measurement of zero-sequence impedance on three phase transformers, measurement of the harmonics of the no-load current, short-circuit withstand test, induced voltage test with partial discharge measurement(IVPD) of 2000kVA 11.3/0.39kV are in accordance with standards and technical contract requirements. The sample passed the above tests.

Approved: Lv Xiangpeng

长祥鹏 2023.05.08

变压器实验室

检验专用章

SHENYANG TRANSFORMER RESEARCH INSTITUTE CO., LTD.



230008349512



中国认可
国际互认
检测
TESTING
CNAS L0681



CHPTL

TYPE TEST REPORT

No : CTQC/B-23. 0111

Test object name: Three-phase oil-immersed distribution transformer

Test object type: 2000kVA 11.3/0.39kV

Entrusted by: Qingdao Cahors Electrical Equipment Co., Ltd.

Manufacturer: Qingdao Cahors Electrical Equipment Co., Ltd.

Kind of testing: Type tests

SHENYANG TRANSFORMER RESEARCH INSTITUTE CO., LTD.

CHINA NATIONAL TRANSFORMER QUALITY DETECTION AND TESTING CENTER



CX-F-01	Test Report	No: CTQC/B-23.0111 Total 30 Page 1
---------	-------------	---------------------------------------

CONTENTS

	Page
1. Certificate of type tests	
2. Test report cover	
3. Contents.....	1
4. Signing and issuing.....	2
5. Test results.....	3~4
6. Test object parameters.....	5
7. Sample condition description.....	5
8. Standards.....	5
9. Test items and conclusions.....	6~30
10. Annex 1: Nameplate and outline photo (Total page 1)	
11. Annex 2: Test circuits (Total page 8)	
12. Annex 3: Transformer drawings (Total pages 2)	

Shenyang Transformer Research Institute Co., Ltd.

China National Transformer Quality Detection And Testing Center

Type Test Report

No: CTQC/B-23. 0111




Total 30 Page 2

Test object name	Three-phase oil-immersed distribution transformer	Test object type	2000kVA 11.3/0.39kV
		Brand	/
Entrusted by	Qingdao Cahors Electrical Equipment Co., Ltd	Kind of testing	Type tests
Manufacturer	Qingdao Cahors Electrical Equipment Co., Ltd	Sampling date	April 12, 2023
		Test date	April 12, 2023 ~ April 19, 2023
Address	197 Ping Shan Road, Qingdao Economic and Technological Development Zone	Serial No	287230009C
Standards	IEC60076-1:2011 IEC60076-2:2011 IEC60076-3:2013 IEC60076-5:2006 Technical contract	Test items	Routine test Type test Measurement of zero sequence impedance of three-phase transformer No-load current harmonic measurement Short-circuit withstand test Partial discharge measurement (IVPD)
Result	<p>The test results of routine tests, type tests, measurement of zero sequence impedance of three-phase transformer, measurement of the harmonics of the no-load current, short-circuit withstand test, induced voltage test with partial discharge measurement of 2000kVA 11.3/0.39kV are in accordance with standards and technical contract. The sample passed the above tests.</p> <p>Signing and issuing date: 2023.5.08</p>		
Note			

Approved by: Lv Xiangpeng

Checked by: Du Jiansong

Compiled by: Song Jialin

- Statement:
1. Testing report is invalid without test special seal.
 2. Testing report is invalid without compiler, checker and approver's signature.
 3. Please inform CTQC in time after received the testing report if you have some disagreement to the testing report.
 4. Testing or witnessing only apply to sample.
 5. Copying testing certificate or testing report is forbidden without written permission from CTQC(except for copying all the testing report).

Test Report				No: CTQC/B-23.0111 Total 30 Page 3	
Test results					
No	Test items	Specified values	Measured values		Conclusions
		Standards(Technical contract)	Before S.C.T	After S.C.T	
1	Measurement of d.c. insulation resistance each winding to earth and between windings (Routine test)	Providing insulation value(MΩ)	H-L.E: 1540 L-H.E: 2110 H.L-E: 1230 H-L: 2530	H-L.E: 1280 L-H.E: 1710 H.L-E: 1060 H-L: 2030	/
2	Measurement of voltage ratio and check of phase displacement (Routine test)	The tolerances of voltage ratio on principal tapping: $\pm 0.5\%$ Connection symbol: Dyn11	-0.05%~-0.02% Dyn11	-0.02%~0.02% Dyn11	Passed
3	Measurement of winding resistance (Routine test)	Providing winding resistance value	See 4.3	See 4.15.3	/
4	Measurement of no-load loss and current (Routine test)	I ₀ %: Providing measured values P ₀ (kW): <1.32	0.17 1.24	0.17 1.24	Passed
5	Measurement of short-circuit impedance and load loss (Routine test)	t: 75°C Z%: 7.6 +10% P _k (kW): <13.5 P _{Total} (kW): <14.82	7.84 12.42 13.66	7.87 12.43 13.67	Passed
6	Test on dielectric liquid (Routine test)	Breakdown voltage (kV): ≥ 40 tan δ (90°C): ≤ 0.05 Water dissolved (mg/L): ≤ 30	59.9 0.02278 15	58.9 0.02279 15	Passed
		Providing gas chromatography	Gas chromatography		
7	Lightning impulse (LI, LIC) (Routine test, special test)	Full wave (kV): 75 $\pm 3\%$ Clipped wave (kV): 85 $\pm 3\%$	/	See 4.15.3.7	Passed
8	Applied voltage test (Routine test)	HV: 28kV 60s LV: 6kV 60s	28kV 60s 6kV 60s	28kV 60s 6kV 60s	Passed
9	Induced voltage withstand test (Routine test)	Applied voltage (kV): 2U _r Induced voltage (kV): 22.6 Duration (s): 120(f _n /f) Frequency (Hz): f > 50	0.78 22.6 40 150	See 4.15.3.9	Passed
10	Tightness tests (Routine test)	Applied pressure (kPa): 20 Duration (h): 24 Residual pressure (kPa): ≥ 14 No oil leakage and damage	20 24 20 No oil leakage and damage		Passed

Test Report		No: CTQC/B-23.0111 Total 30 Page 4			
№	Test items	Specified values	Measured values		Conclusions
		Standards(Technical contract)			
11	Measurement of no-load loss and current at 90% and 110% of rated voltage (Routine test)	I ₀ %: Providing measured values P ₀ (kW): Providing measured values	90% 0.10 0.98	110% 0.29 1.58	/
12	Measurement of the harmonics of the no-load current (Special test)	Provides harmonic values of no-load current in each phase	See 4.12		/
13	Determination of sound level (Type test)	Sound pressure level \overline{L}_{PA} dB(A): / Sound power level $L_{WA, SN}$ dB(A): ≤ 53	39 52		Passed
14	Temperature rise test (Type test)	Top oil temp.-rise limit (K): 45 Winding temp.-rise limit (K): 50	Top oil: 41.3 HV: 40.8 LV: 43.4		Passed
15	Short-circuit withstand test (Special test)	Three times each phase Duration(s): $1.0 \pm 10\%$ Test waveshapes have no distortion Deviation of reactance before and after S.C.T.: $\pm 4.0\%$ The untanking inspection shows no apparent defects Successfully check items after S.C.T.	3 times 1.0 No distortion 0.21% No apparent defects Passed		Passed
16	Measurement of zero-sequence impedance on three-phase transformers (Special test)	Providing zero-sequence impedance(Ω)	0.00616		/
17	Induced voltage test with partial discharge measurement (IVPD) (Special test)	$U_1=2.0U_r/\sqrt{3}$ (kV) Duration (s): 120 (f_n/f)	13.048 40		Passed
		$U_2=1.58U_r/\sqrt{3}$ (kV) Duration (min): 60 Partial discharge(pC): <50	10.308 60 <15		
		$1.2U_r/\sqrt{3}$ (kV) Duration (min): 1 Partial discharge (pC): <50	7.829 1 <15		
		$0.4U_r/\sqrt{3}$ (kV) Duration (min): / Partial discharge (pC): <50	2.610 / <15		
		Frequency (Hz): >50	150		

Test Report		No: CTQC/B-23.0111 Total 30 Page 5												
<p>1. Test object parameters</p> <p>Rated power: 2000kVA Rated voltage: 11.3/0.39kV Rated current: 102.19/2960.77A Highest voltage for equipment: 12kV Rated frequency: 50Hz Number of phases: 3 Connection symbol: Dyn11 Cooling method: KNAN Altitude: ≤ 1000 m Temperature class of insulation: E</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 30%;">Insulation level:</td> <td style="width: 20%;">HV</td> <td style="width: 20%;">Um/ LI/LIC/AC</td> <td style="width: 30%;">12/75/85/28kV</td> </tr> <tr> <td></td> <td>LV</td> <td>Um/AC</td> <td>1.1/6kV</td> </tr> </table> <p>2. Sample condition description</p> <p>Sample exterior construction and major dimensions(length, width, height)are in compliance with drawings。 Measured values: length 2329 mm, width 2197 mm, height 2200 mm。 Drawing confirmation</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%; text-align: center;">Outline</th> <th style="width: 50%; text-align: center;">Nameplate</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">4600009234</td> <td style="text-align: center;">40136169R14</td> </tr> </tbody> </table> <p>Rating plate and outline drawings are in testing report annex, other drawings should be conserved by enterprise after affirming by CTQC. The design, performance data, specifications of sample rating plate are in compliance with drawing. The marking of the phase sequence on HV and LV side of the sample is clear and right. The surface of the sample has no collision and damage.</p> <p>3. Standards</p> <p>IEC60076-1:2011 Power transformers Part 1: General IEC60076-2:2011 Power transformers Part 2: Temperature rise for liquid-immersed transformers IEC60076-3:2013 Power transformers Part 3: Insulation levels, dielectric tests and external clearances in air IEC60076-5:2006 Power transformers Part 5 Ability to withstand short-circuit Technical contract</p>			Insulation level:	HV	Um/ LI/LIC/AC	12/75/85/28kV		LV	Um/AC	1.1/6kV	Outline	Nameplate	4600009234	40136169R14
Insulation level:	HV	Um/ LI/LIC/AC	12/75/85/28kV											
	LV	Um/AC	1.1/6kV											
Outline	Nameplate													
4600009234	40136169R14													

Test Report					No: CTQC/B-23.0111 Total 30 Page 6	
4. Test items and conclusions						
4.1 Measurement of d.c. insulation resistance each winding to earth and between windings (Routine test)						
Test date: April 12, 2023						
Humidity: 38.2%; Oil temperature: 15.5°C; Atmospheric pressure: 100.0kPa						
Measured position			Insulation resistance (MΩ)			
HV-LV&E			1540			
LV-HV&E			2110			
HV, LV-E			1230			
HV-LV			2530			
4.2 Measurement of voltage ratio and check of phase displacement (Routine test)						
Test date: April 12, 2023						
Oil temperature: 15.5°C						
HV winding	LV winding	Ratio	Measured deviation (%)			Connection symbol
Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
11.3	0.39	28.974	-0.02	-0.05	-0.05	Dyn11
Result: Passed.						
4.3 Measurement of winding resistance (Routine test)						
Test date: April 12, 2023						
Oil temperature: 15.5°C						
Winding		d.c. resistance (Ω)				
HV		A~B	B~C	C~A		
		0.19042	0.19017	0.19023		
LV		a~b	b~c	c~a		
		0.0002996	0.0002925	0.0003106		
4.4 Measurement of no-load loss and current (Routine test)						
The test circuit is shown in Annex 2-a						
Test date: April 12, 2023						
Oil temperature: 15.5°C						
Voltage multiple	Applied voltage (kV)		No-load current		No-load loss (kW)	
	Mean value	R.M.S.	(A)	(%)	Measured value	Corrected value
90%Ur	0.203	0.203	3.04	0.10	0.98	0.98
100%Ur	0.225	0.226	5.09	0.17	1.25	1.24
110%Ur	0.248	0.249	8.60	0.29	1.59	1.58
Result: Passed.						

Test Report						No.: CTQC/B-23.0111 Total 30 Page 7		
4.5 Measurement of short-circuit impedance and load loss (Routine test) The test circuit is shown in Annex 2-b						Test date: April 12, 2023		
Winding	Applied current		Measured voltage (kV)	Short-circuit impedance (Each phase)		Load loss (kW)		Total losses (kW)
				(Ω)	(%)	Measured value	Corrected value	Corrected value
	I (A)	I/Ir (%)		t=75°C	t=75°C I=Ir	t=15.5°C	t=75°C I=Ir	t=75°C I=Ir
HV LV	59.75	58.47	0.518	5.01	7.84	3.99	12.42	13.66
Result: Passed.								
4.6 Test on dielectric liquid (Routine test)						Test date: April 12, 2023 Ambient temperature: 21.6°C		
tan δ (90°C)			Breakdown voltage (kV)			Water dissolved (mg/L)		
0.02278			59.9			15		
Gas chromatography (After temperature rise test)						Test date: April 17, 2023		
μ L/L								
H ₂	CO	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbon	
48.46	18.07	250.97	1.24	51.17	0.44	0.00	52.85	
Result: Passed.								
4.7 Lightning impulse test (Type test, special test) The tests were performed after the short-circuit withstand test, see 4.15.3.7.								
4.8 Applied voltage test (Routine test)						Test date: April 17, 2023		
The test circuit is shown in Annex 2-c Humidity: 38.2%; Oil temperature: 15.5°C; Atmospheric pressure: 100.0kPa								
Measured position		Applied voltage (kV)		Duration (s)		Result		
HV-LV&E		28		60		Passed		
LV-HV&E		6		60				

Test Report					No: CTQC/B-23.0111 Total 30 Page 8	
4.9 Induced voltage withstand test (Routine test)					Test date: April 12,2023	
The test circuit is shown in Annex 2-d					Humidity: 38.2%; Oil temperature: 15.5°C; Atmospheric pressure: 100.0kPa	
Applied voltage (kV)	Induced voltage (kV)	Induced multiple	Frequency (Hz)	Duration (s)	Result	
LV	HV					
0.78	22.6	2	150	40	Passed	
4.10 Tightness tests (Routine test)					Test date: April 18,2023 Ambient temperature: 15.3°C	
Test method	Applied pressure (kPa)	Duration (h)	Residual pressure (kPa)	Result		
Atmosphere pressure method	20	24	20	No leakage oil and damage, Passed		
4.11 Measurement of no-load loss and current at 90% and 110% of rated voltage (Type test)						
See 4.4.						

<h2 style="margin: 0;">Test Report</h2>	№: CTQC/B-23.0111 Total 30 Page 9
---	--------------------------------------

4.12 Measurement of the harmonics of the no-load current (Special test)
 The test circuit is shown in Annex 2-e

Test date: April 12,2023
 Oil temperature: 12.9°C

Or.	U1 [V]	hdf[%]	I1 [A]	hdf[%]
Tot.	225.22		5.643	
dc				
1	225.21	100.000	5.513	100.000
2	0.16	0.072	0.100	1.822
3	0.94	0.419	0.272	4.939
4	0.08	0.035	0.035	0.632
5	1.80	0.800	1.139	20.663
6	0.01	0.004	0.004	0.071
7	0.17	0.077	0.234	4.249
8	0.11	0.047	0.008	0.153
9	0.41	0.181	0.047	0.845
10	0.06	0.027	0.007	0.125
11	0.48	0.215	0.032	0.585
12	0.05	0.021	0.005	0.089
13	0.67	0.296	0.048	0.874
14	0.03	0.012	0.002	0.045
15	0.09	0.041	0.076	1.378
16	0.01	0.004	0.002	0.034
17	0.03	0.013	0.010	0.177
18	0.00	0.000	0.001	0.022
19	0.19	0.086	0.023	0.426
20	0.01	0.005	0.001	0.024

Or.	U2 [V]	hdf[%]	I2 [A]	hdf[%]
Tot.	226.50		4.343	
dc				
1	226.48	100.000	4.162	100.000
2	0.08	0.037	0.089	2.149
3	1.40	0.618	0.522	12.554
4	0.07	0.030	0.040	0.950
5	2.00	0.883	1.077	25.889
6	0.03	0.013	0.004	0.090
7	0.15	0.067	0.278	6.672
8	0.03	0.013	0.004	0.108
9	0.20	0.090	0.016	0.375
10	0.08	0.034	0.007	0.159
11	1.90	0.839	0.094	2.254
12	0.08	0.035	0.001	0.013
13	0.42	0.185	0.050	1.212
14	0.03	0.011	0.003	0.063
15	0.06	0.027	0.082	1.977
16	0.01	0.004	0.003	0.067
17	0.05	0.021	0.008	0.184
18	0.00	0.000	0.000	0.012
19	0.17	0.076	0.022	0.519
20	0.01	0.004	0.000	0.009

Or.	U3 [V]	hdf[%]	I3 [A]	hdf[%]
Tot.	224.81		5.274	
dc				
1	224.79	100.000	5.112	100.000
2	0.11	0.051	0.094	1.834
3	0.60	0.265	0.480	9.382
4	0.04	0.019	0.037	0.732
5	1.80	0.799	1.171	22.897
6	0.03	0.015	0.003	0.049
7	0.17	0.077	0.231	4.515
8	0.07	0.032	0.005	0.107
9	0.21	0.092	0.025	0.492
10	0.11	0.048	0.007	0.146
11	1.85	0.822	0.093	1.827
12	0.08	0.037	0.004	0.073
13	0.35	0.157	0.020	0.392
14	0.04	0.019	0.002	0.048
15	0.04	0.018	0.078	1.523
16	0.01	0.005	0.003	0.066
17	0.09	0.040	0.004	0.083
18	0.01	0.004	0.001	0.010
19	0.17	0.075	0.024	0.471
20	0.01	0.005	0.001	0.019

Test Report				№: CTQC/B-23.0111 Total 30 Page 10	
4.13 Determination of sound level (Type test)				Test date: April 14,2023	
4.13.1 Sound power level calculation under on load current					
Calculation equation:					
$L_{WA,IN}=39+18\lg\frac{S_r}{S_p}\approx 44\text{dB (A)}$					
In which: S_r —Rated power : 2MVA;					
S_p —Base power : 1MVA。					
$L_{WA,IN}$ is found to be 9dB(A) below the guaranteed sound power level 53dB(A), according to standard, the load current sound measurements are not appropriate.					
4.13.2 Sound level measurement and sound power level calculation					
Transformer was energized at rated voltage.The outline was 0.3m away from the principal radiating surface, there were 10 measured points, the measured point interval was 0.98m, the height of oil tank was 1.65m, the heights of measured points were 0.83m.					
Environmental conditions				Oil temperature: 16.7℃	
Area of the surface of the test room S_v (m ²)	Mean sound absorption coefficient α	Sound Absorption (m ²)	Distance from the reference transmitting surface (m)	Area of effective surface S (m ²)	Environmental corrected value factor K dB (A)
2300	0.2	460	0.3	20.21	0.7
Test results					dB (A)
Cooling method	The average noise level of background		The average noise level of transformer $\overline{L_{PAO}}$	A-weighted surface sound pressure level $\overline{L_{PA}} = 10\lg(10^{0.1\overline{L_{PAO}}} - 10^{0.1\overline{L_{bgA}}}) - K$	A-weighted sound power level $L_{WA,UN} = \overline{L_{PA}} + 10\lg(S/S_0)$
	Before	Before			
KNAN	30.3	30.4	40.2	39	52
<p>Note: $\overline{L_{PAO}}$: Uncorrected average A-weighted sound pressure level; $\overline{L_{PAO}} = 10\lg\left(\frac{1}{N} \sum_{i=1}^N 10^{0.1L_{PAi}}\right)$</p> <p>$\overline{L_{bgA}}$: The lower of the two calculated average A-weighted background sound pressure level.</p> <p>Result: Passed.</p>					

Test Report		No: CTQC/B-23.0111 Total 30 Page 11	
4.14 Temperature rise test (Type test)		Test date: April 14,2023	
<p>The test was conducted by means of short-circuit method. The test duration was 13h, stability duration was 3h. Measuring top oil temperature rise: the specified total losses was 13.67kW, injected total losses of 13.64kW Measuring winding temperature rise: the specified current was 102.19A, injected current of 105.9A during the test.</p>			
		Conclusions of temperature rise	Ambient temperature: 17.2°C
Top oil temperature rise(K)			41.3
Winding temperature rise(K)	HV	40.8	
	LV	43.4	
<p>Note: The results of temperature rise were corrected value at specified total losses and current. Result: Passed.</p>			

Test Report

№: CTQC/B-23.0111
Total 30 Page 12

Legend: Data to be inserted

Time interval	$\Delta t = 1$ min		Estimated winding time constant	Tw= 23.25 min
Initial average liquid temp.	$\theta_{om_start} = 50.2$ °C		Estimated average liquid temp.	Ao= 51.47 °C
Final average-liquid temp.	$\theta_{om_end} = 47.5$ °C		Estimated winding to liquid temp.	B= 7.02 K
Liquid temperature slope	k= 0.14 K/min		Average winding temp. at the instant of shut down	$\theta_{wo} = 58.5$ °C

Auxiliary variables:

tc= -2.2624
te= 0.0440

	n	sa	sb	sc	sd	se
Abs Sums:	18	3.47	1005.41	194.59	56175.43	11.25

Time (min)	R(i) (Ω) × 10 ⁻¹	$\theta_{om}(i) = A_o - kt$	$\theta_{wm}(i)$ as measured	$\theta_{wval}(i)$	$\theta_{wcor}(i)$	$u \left\{ \frac{-}{(0/1)} \right\}$	$\theta_w(i)$ as corrected and validated	$\Delta\theta_w(i)$ as per eq. (C.5)	$\theta_w(i) \times \Delta\theta_w(i)$	$(\theta_w(i))^2$	e^{-i/T_w}	$\theta_w(i)$ as calculated
0		51.47										58.49
1		51.34										58.06
2	2.232	51.20	57.65	57.65	57.92	1						57.64
3	2.229	51.07	57.25	57.25	57.66	1	57.66	-0.258	-14.90	3324.52	0.8789	57.23
4	2.226	50.93	56.86	56.86	57.40	1	57.40	-0.258	-14.83	3294.79	0.8419	56.84
5	2.223	50.80	56.47	56.47	57.14	1	57.14	-0.258	-14.76	3265.20	0.8065	56.45
6	2.220	50.66	56.07	56.07	56.88	1	56.88	-0.258	-14.70	3235.74	0.7725	56.08
7	2.217	50.53	55.68	55.68	56.63	1	56.63	-0.258	-14.63	3206.42	0.7400	55.72
8	2.215	50.39	55.28	55.28	56.37	1	56.37	-0.127	-7.19	3192.03	0.7088	55.36
9	2.212	50.26	54.89	54.89	56.11	1	56.11	-0.258	-14.53	3162.90	0.6790	55.02
10	2.209	50.12	54.50	54.50	55.85	1	55.85	-0.258	-14.46	3133.91	0.6504	54.68
11	2.207	49.99	54.11	54.11	55.59	1	55.59	-0.127	-7.11	3119.68	0.6230	54.36
12	2.204	49.85	53.72	53.72	55.33	1	55.33	-0.258	-14.36	3090.89	0.5968	54.04
13	2.202	49.72	53.33	53.33	55.07	1	55.07	-0.127	-7.06	3076.76	0.5717	53.73
14	2.200	49.58	52.94	52.94	54.81	1	54.81	-0.127	-7.04	3062.66	0.5476	53.42
15	2.198	49.45	52.55	52.55	54.55	1	54.55	-0.127	-7.02	3048.60	0.5245	53.13
16	2.195	49.31	52.16	52.16	54.29	1	54.29	-0.258	-14.20	3020.13	0.5024	52.84
17	2.193	49.18	51.77	51.77	54.03	1	54.03	-0.127	-6.98	3006.17	0.4813	52.55
18	2.191	49.04	51.38	51.38	53.77	1	53.77	-0.127	-6.96	2992.23	0.4610	52.28
19	2.189	48.91	50.99	50.99	53.51	1	53.51	-0.127	-6.94	2978.33	0.4416	52.00
20	2.187	48.77	50.60	50.60	53.25	1	53.25	-0.127	-6.93	2964.46	0.4230	51.74
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												

H.V. Winding temp.-rise (K): $\Delta\theta_{WH} = (\theta_{wo} - \theta_{om_star}) \times \left(\frac{I_{rated}}{I_{start}} \right)^y + \Delta\theta_{om} = (58.5 - 50.2) \times \left(\frac{102.19}{105.9} \right)^{1.6} + 33.0 = 40.8$

Test Report	№: CTQC/B-23.0111 Total 30 Page 13
-------------	---------------------------------------

Legend: Data to be inserted

Time interval	Δt= 1 min		
Initial average liquid temp.	θ _{om_start} = 50.2 °C	Estimated winding time constant	T _w = 5.56 min
Final average-liquid temp.	θ _{om_end} = 47.5 °C	Estimated average liquid temp.	A _o = 52.22 °C
Liquid temperature slope	k= 0.14 K/min	Estimated winding to liquid temp.	B= 8.96 K
Auxiliary variables:		Average winding temp. at the instant of shut down	θ _{w0} = 61.2 °C

tc= -10.2796		n	sa	sb	sc	sd	se
te= 0.1969	Abs Sums:	18	6.01	970.41	330.79	52350.98	3.41

Time (min)	R(i) (Ω) ×10 ⁻⁴	θ _{om} (i)= A _o -kt	θ _{wm} (i) as measured	θ _{wval} (i)	θ _{wcor} (i)	u{ ₋ (0/1)	θ _w (i) as corrected and validated	Δθ _w (i) as per eq. (C.5)	θ _w (i) × Δθ _w (i)	(θ _w (i)) ²	e ^(-i/T_w)	θ _w (i) as calculated
0		52.22										61.18
1		52.08										59.57
2	3.437	51.95	58.05	58.05	58.32	1						58.20
3	3.422	51.81	56.77	56.77	57.18	1	57.18	-1.144	-65.41	3269.46	0.5833	57.04
4	3.410	51.68	55.75	55.75	56.29	1	56.29	-0.888	-50.00	3168.68	0.4873	56.04
5	3.401	51.54	54.98	54.98	55.66	1	55.66	-0.632	-35.20	3097.88	0.4072	55.19
6	3.394	51.41	54.39	54.39	55.20	1	55.20	-0.462	-25.49	3046.69	0.3402	54.45
7	3.387	51.27	53.79	53.79	54.73	1	54.73	-0.462	-25.28	2995.91	0.2842	53.82
8	3.382	51.14	53.36	53.36	54.44	1	54.44	-0.291	-15.86	2964.11	0.2375	53.26
9	3.376	51.00	52.85	52.85	54.07	1	54.07	-0.377	-20.36	2923.24	0.1984	52.78
10	3.372	50.87	52.51	52.51	53.86	1	53.86	-0.206	-11.10	2901.00	0.1658	52.35
11	3.368	50.73	52.17	52.17	53.65	1	53.65	-0.206	-11.06	2878.85	0.1385	51.97
12	3.364	50.60	51.83	51.83	53.45	1	53.45	-0.206	-11.01	2856.78	0.1157	51.63
13	3.360	50.46	51.49	51.49	53.24	1	53.24	-0.206	-10.97	2834.80	0.0967	51.33
14	3.356	50.33	51.15	51.15	53.04	1	53.04	-0.206	-10.93	2812.90	0.0808	51.05
15	3.353	50.19	50.89	50.89	52.92	1	52.92	-0.121	-6.39	2800.10	0.0675	50.80
16	3.350	50.06	50.64	50.64	52.80	1	52.80	-0.121	-6.38	2787.33	0.0564	50.56
17	3.347	49.92	50.38	50.38	52.67	1	52.67	-0.121	-6.36	2774.59	0.0471	50.34
18	3.343	49.79	50.04	50.04	52.47	1	52.47	-0.206	-10.81	2752.92	0.0394	50.14
19	3.341	49.65	49.87	49.87	52.43	1	52.43	-0.036	-1.86	2749.20	0.0329	49.95
20	3.338	49.52	49.61	49.61	52.31	1	52.31	-0.121	-6.32	2736.54	0.0275	49.76
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												


L.V. Winding temp.-rise (K): $\Delta\theta_{wL} = (\theta_{w0} - \theta_{om_star}) \times \left(\frac{I_{rated}}{I_{start}}\right)^y + \Delta\theta_{om} = (61.2 - 50.2) \times \left(\frac{102.19}{105.9}\right)^{1.6} + 33.0 = 43.4$

Test Report

No: CTQC/B-23.0111

Total 30 Page 14


Temperature curve



Test Report

No: CTQC/B-23.0111
Total 30 Page 15

Temperature curve



Test Report							№: CTQC/B-23.0111 Total 30 Page 16			
4.15 Short-circuit withstand test (Special test)							Test date: April 12,2023			
4.15.1 Calculated short-circuit current (reference temperature 75°C)							Ambient temperature: 14.5°C			
The first peak of the asymmetrical phase short-circuit current (A)	The r.m.s. value of the symmetrical phase short-circuit current (A)			The r.m.s. value of the symmetrical line short-circuit current (A)			Peak factor ($K\sqrt{2}$)			
1803	716			1240			2.518			
4.15.2 Measurement of short-circuit current										
The test circuit is shown in Annex 2-f										
Perform single-phase test, the voltage was applied between two corners of the delta, total 9 times. Test waveshapes had no distortion, test oscillograms were shown in pages 26~28. The percentage for the first peak of the phase asymmetrical phase short-circuit value and the r.m.s. value of the phase symmetrical short-circuit current is the ratio of measured current to calculated current.										
Corrected value = measured value /1.5										
Applied voltage terminal	№.	Measurement of current							Duration (s)	Waveform serial №
		The first peak of the asymmetrical phase short-circuit current			The r.m.s. value of the symmetrical phase short-circuit current					
		Measured value (A)	Corrected value (A)	(%)	Measured value(A)	Corrected Value(A)	(%)			
AB	1	2669	1779	98.7	987	658	91.9	1.0	B230111-S01-1	
	2	2684	1789	99.2	988	659	92.0	1.0	B230111-S01-2	
	3	2687	1791	99.3	989	659	92.0	1.0	B230111-S01-3	
	№.	Measurement of reactance								
		Phase reactance value(Ω)			Deviation of phase reactance(%)					
	A	B	C	A	B	C				
	Before	14.71	14.55	14.95	/	/	/			
	1	14.67	14.54	14.92	-0.27	<0.1	-0.20			
	2	14.68	14.55	14.93	-0.20	<0.1	-0.13			
3	14.69	14.55	14.93	-0.14	<0.1	-0.13				

Test Report								№: CTQC/B-23.0111 Total 30 Page 17		
Applied voltage terminal	№.	Measurement of current							Duration (s)	Waveform serial №
		The first peak of the asymmetrical phase short-circuit current			The r.m.s. value of the symmetrical phase short-circuit current					
		Measured value (A)	Corrected value(A)	(%)	Measured value(A)	Corrected Value(A)	(%)			
BC	1	2670	1780	98.7	986	657	91.8	1.0	B230111-S02-1	
	2	2667	1778	98.6	985	657	91.8	1.0	B230111-S02-2	
	3	2673	1782	98.8	986	957	91.8	1.0	B230111-S02-3	
	№.	Measurement of reactance								
		Phase reactance value (Ω)			Phase reactance deviation (%)					
		A	B	C	A	B	C			
	Before	14.71	14.55	14.95	/	/	/			
	1	14.73	14.56	14.93	0.14	<0.1	-0.13			
2	14.73	14.57	14.93	0.14	0.14	-0.13				
3	14.73	14.58	14.93	0.14	0.21	-0.13				
Applied voltage terminal	№.	Measurement of current							Duration (s)	Waveform number
		The first peak of the asymmetrical phase short-circuit current			The r.m.s. value of the symmetrical phase short-circuit current					
		Measured value (A)	Corrected value(A)	(%)	Measured value(A)	Corrected value (A)	(%)			
CA	1	2720	1813	100.6	1005	670	93.6	1.0	B230111-S03-1	
	2	2729	1819	100.9	1005	670	93.6	1.0	B230111-S03-2	
	3	2737	1825	101.2	1007	671	93.7	1.0	B230111-S03-3	
	№.	Measurement of reactance								
		Phase reactance value (Ω)			Phase reactance deviation (%)					
		A	B	C	A	B	C			
	Before	14.71	14.55	14.95	/	/	/			
	1	14.71	14.58	14.91	<0.1	0.21	-0.27			
2	14.72	14.59	14.92	<0.1	0.27	-0.20				
3	14.72	14.58	14.93	<0.1	0.21	-0.13				
Measurement of short-circuit reactance after S.C.T.										
Phase reactance value (Ω)			Phase reactance deviation (%)							
A	B	C	A	B	C					
14.72	14.58	14.93	<0.1	0.21	-0.13					
The maximum phase reactance deviation was 0.21%.										

Test Report				No: CTQC/B-23.0111 Total 30 Page 18		
4.15.3 Repeated routine tests after short-circuit withstand test						
4.15.3.1 Measurement of d.c. insulation resistance each winding to earth and between windings						
Test date: April 14, 2023						
Humidity: 38.3%; Oil temperature: 16.7°C; Atmospheric pressure: 100.4kPa						
Measured position			Insulation resistance (MΩ)			
HV-LV&E			1280			
LV-HV&E			1710			
HV, LV-E			1060			
HV-LV			2030			
4.15.3.2 Measurement of voltage ratio and check of phase displacement						
Test date: April 14, 2023						
Oil temperature: 16.7°C						
HV winding	LV winding	Ratio	Measured deviation(%)			Connection symbol
Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
11.3	0.39	28.974	0.02	-0.02	0.02	Dyn11
Result: Passed.						
4.15.3.3 Measurement of winding resistance						
Test date: April 14, 2023						
Oil temperature: 16.7°C						
Winding	d.c. resistance(Ω)					
HV	A~B	B~C	C~A			
	0.19217	0.19197	0.19204			
LV	a~b	b~c	c~a			
	0.0003000	0.0002952	0.0003123			
4.15.3.4 Measurement of no-load loss and current						
Test date: April 15, 2023						
Oil temperature: 16.7°C						
Applied voltage (kV)		No-load current		No-load loss (kW)		
Means value	R.M.S.	(A)	(%)	Measured value	Corrected value	
0.225	0.224	5.12	0.17	1.23	1.24	
Result: Passed.						

Test Report						No: CTQC/B-23.0111 Total 30 Page 19		
4. 15. 3. 5 Measurement of short-circuit impedance and load loss						Test date: April 15,2023		
Winding	Applied current		Measured voltage (kV)	Short-circuit impedance (Each phase)		Load loss (kW)		Total losses (kW)
	I (A)	I/Ir (%)		(Ω)	(%)	Measured value	Corrected value	Corrected value
				t=75°C	t=75°C I=Ir	t=16.7°C	t=75°C I=Ir	t=75°C I=Ir
HV LV	59.83	58.55	0.520	5.02	7.87	4.01	12.43	13.67
Result: Passed								
4. 15. 3. 6 Test on dielectric liquid						Test date: April 14,2023 Ambient Temperature: 21.6°C		
tanδ(90°C)			Breakdown voltage(kV)			Water dissolved(mg/L)		
0.02279			58.9			15		
Result: Passed								






Test Report			No: CTQC/B-23.0111 Total 30 Page 20
4.15.3.7 Lightning impulse test (LI, LIC)			Test date: April 14,2023
The test circuit is shown in Annex 2-g			
Test atmospheric conditions: Humidity: 38.5%; Ambient temperature: 15.2°C; Atmospheric pressure: 101.2kPa			
Test items and voltage			
Tested terminals	Rated withstand voltage(kV)		Tap position
	Full	Chopped	
A, B, C	75	85	/
<p>Note: According to the requirements of the technical service contract, lightning full wave impact test shall be carried out before the short-circuit bearing capacity test.</p> <p>Test voltage: Full wave(kV): 73.25~75.77kV Chopped wave(kV): 84.96~85.70kV</p> <p>Line terminal</p> <p>One reduced negative polarity full wave impulse;; One rated negative polarity full wave impulse; Two rated negative polarity chopped wave impulses; Two rated negative polarity full wave impulses;</p> <p>Test oscillogram records: T1: Front time; T2:Time to half value; Tc: Time to chopping; Up: Peak voltage. Up2: Time to zero.</p> <p>Result: Passed</p>			

Test Report

No.: CTQC/B-23.0111

Total 30 Page 21

Tested terminal: A; Test polarity: Negative CH1: Voltage records CH2: Neutral current records









Test Report

No.: CTQC/B-23.0111

Total 30 Page 22

Tested terminal: B; Test polarity: Negative CH1: Voltage records CH2: Neutral current records









Test Report

No.: CTQC/B-23.0111

Total 30 Page 23

Tested terminal: C; Test polarity: Negative CH1: Voltage records CH2: Neutral current records




Test Report				No.: CTQC/B-23.0111 Total 30 Page 24	
4.15.3.8 Applied voltage test				Test date: April 14,2023	
Humidity: 38.3%;Ambient temperature: 16.7°C; Atmospheric pressure: 100.4kPa					
Measured position	Test voltage (kV)	Duration (s)	Result		
ABC	28	60	Passed		
abcn	6	60			
4.15.3.9 Induced voltage withstand test See 4.17.					
4.15.4 The out of tank inspection There is no deformation of winding, connection and supporting structures, no traces of electrical discharge was found after S.C.T. The active part photos taken before and after S.C.T. were shown in pages 29~30. See page 29~30 for photos of hanging core before and after the test.					
4.15.5 The result of short-circuit withstand test: passed.					
4.16 Measurement of zero-sequence impedance on three-phase transformers (Special test) Test date: April 14,2023 The test circuit is shown in Annex 2-h Oil temperature: 16.7°C					
Connection symbol	Power supply terminal	Open terminal	Applied current (A)	Measured voltage (V)	Zero-sequence impedance (Ω)
Dyn11	abc-n	A, B, C	501.04	1.029	0.00616

Test Report				No.: CTQC/B-23.0111 Total 30 Page 25		
4.17 Induced voltage test with partial discharge measurement (IVPD) (Special test)						
						Test date: April 14, 2023
Test frequency :150Hz						Oil temperature: 16.7°C
Applied voltage (kV)			Duration	Local discharge (pC)		
Multiple	HV	LV		A	B	C
$0.4U_r/\sqrt{3}$	2.610	0.090	/	<10	<15	<10
$1.2U_r/\sqrt{3}$	7.829	0.270	1min	<10	<15	<10
$U_2=1.58U_r/\sqrt{3}$	10.308	0.356	5min	<10	<15	<10
$U_1=2.0U_r/\sqrt{3}$	13.048	0.450	40s	/	/	/
$U_2=1.58U_r/\sqrt{3}$	10.308	0.356	5min	<10	<15	<10
			10min	<10	<15	<10
			15min	<10	<15	<10
			20min	<10	<15	<10
			25min	<10	<15	<10
			30min	<10	<15	<10
			35min	<10	<15	<10
			40min	<10	<15	<10
			45min	<10	<15	<10
			50min	<10	<15	<10
55min	<10	<15	<10			
60min	<10	<15	<10			
$1.2U_r/\sqrt{3}$	7.829	0.270	1min	<10	<15	<10
$0.4U_r/\sqrt{3}$	2.610	0.090	/	<10	<15	<10
Note: $U_1=2.0U_r/\sqrt{3}$ instead of inductive voltage withstand test						
Result: Passed						

Test Report

No.: CTQC/B-23.0111

Total 30 Page 26




B230111-S01

Test Report

No: CTQC/B-23.0111


Total 30 Page 27



Test Report

No.: CTQC/B-23.0111

Total 30 Page 28



B230111-S03

HV side before test:



LV side before test:



Test

Report

No: CTQC/B-23.0111

Total 30 Page 30

HV side after test:




LV side after test:



NAMEPLATE AND OUTLINE PHOTOS


Nameplate:



Outline:




SCHEMATIC DIAGRAM OF TEST CIRCUIT



空载损耗及空载电流测量线路图

No-load loss and current measurement circuit

T-被试变压器 Sample CT-电流互感器 Current transformer
 PT-电压互感器 Voltage transformer A-电流表 Amperemeter
 W-瓦特表 Wattmeter V-电压表 Voltmeter



短路阻抗及负载损耗测量线路图

Short circuit impedance and on load loss measurement circuit

T-被试变压器 Sample


CT-电流互感器 Current transformer

A-电流表 Amperemeter

PT-电压互感器 Voltage transformer

W-瓦特表 Wattmeter


V-电压表 Voltmeter



外施耐压试验线路图

Separate-source voltage withstand diagram


- | | | | | | |
|-------------|----------------------|------------|----------------------|----------|---------------------|
| T-调压器 | Regulator | A-电流表 | Amperemeter | Bs-试验变压器 | Testing transformer |
| CT-电流互感器 | Current transformer | V1, V2-电压表 | Voltmeter | | |
| C1, C2-分压电容 | Capacitive divider | Cz-试品 | Sample | | |
| r-放电电阻 | Discharge resistance | Vp-峰值电压表 | Peak value voltmeter | | |



感应耐压试验线路图

Induced overvoltage withstand test circuit


- | | | | |
|----------|---------------------|----------|---------------------|
| T-被试变压器 | Sample | CT-电流互感器 | Current transformer |
| PT-电压互感器 | Voltage transformer | A-电流表 | Amperemeter |
| V-电压表 | Voltmeter | | |



短路承受能力试验线路图

Short circuit tests of transformer:

- IT: 中间变压器 Intermediate transformer CT: 电流互感器 Standard current transformer PC: 计算机 Computer
 L: 限流电抗器 Reactors PT: 电压互感器 Voltage transformer DL850: 瞬态记录仪 16 channels analyzer
 S: 被试变压器 Sample NOB, NM, NBA, NB2: SF6断路器 SF6 switchgear



雷冲试验线路图
Lightning impulse withstand test system circuit

- | | | | |
|---------------|-----------------------------------|---------|------------------------|
| G-冲击电压发生器 | Impulse generator | G1-截断装置 | Chopping device |
| Z1, Z2-阻容分压器 | Voltage divider | M-测量仪器 | Measurement instrument |
| L1, L2-高频传输电缆 | High frequency transmission cable | T-试品 | Sample |
| r-分流器 | Shunt | | |

TRANSFORMER DRAWINGS

Handwritten notes and drawings in blue ink at the top left of the page.

124

4-∅ 5

CAHORS

QINGDAO CAHORS ELECTRICAL EQUIPMENT CO., LTD
 197, Pingshan Road, Qingdao E & T Dept Zone, 266500, Qingdao, Shandong, China
 Tel: +86(0)532 8690 7072 Fax: +86(0)532 8690 7122

TRANSFORMER

LOSSES **HERMETICALLY SEALED** Hz

ACCORDING TO

REFERENCE N°

YEAR **MAGNETIC CORE** **FeSi** kg

CONDUCTOR **COPPER** kg **ALUMINIUM** kg

INSULATION LEVELS **HV** **LV** kv

RATED POWER kVA

CONNECTION SYMBOL

IMPEDANCE VOLTAGE % **MAX AMBIENT TEMP.** °C

TEMPERATURE RISE **OIL** K **WINDING** K

HIGH VOLTAGE
 V A

LOW VOLTAGE

1	NA	V	NA	A
2	NA	V	NA	A
3	390	V	2961	A
4	NA	V	NA	A
5	NA	V	NA	A


COOLING

DIELECTRIC TYPE **DIELECTRIC MASS** kg

DIELECTRIC VOLUME L **TOTAL MASS** kg

MADE IN

235



NOTES
 1. Material: 316L thickness: 1mm;
 2. The blank tolerance with * is ±5%;
 3. Impedance voltage will imprint measured value.

01				
00	2022/11/29	YY.Cheng		
NO	DATE	DESIGN	CHECK	REASON FOR MODIFICATION

PLATE NAME ENG 316L


Propriété de la société TRANSFIX, ce document ne peut être ni reproduit, ni copié, ni communiqué à des tiers sans autorisation écrite de celle-ci.



ECH: 1:1.5
 Format A4

40136169R14 | 00

林 3月14日



Oil Weight(kg) 1450
Total weight(kg) 7850

No.	Item	Description	QTY	Maker
21	Sampling Valve	L14N-C	1	Checkfluid INC
20	LV Cable bracket	Adjustable by 100mm	1	QCEE
19	Alarm terminal box	IP55	1	QCEE
18	Auxiliary supply Fuse box	IP55 with lock and handle	1	QCEE
17	Drain Valve	Gate valve with sampling	1	QCEE
16	Fluid Plate	BS316L	2	QCEE
15	Rating Plate	BS316L	1	QCEE
14	LV Cable box	IPX2 with view window	1	QCEE
13	HV Cable box	IP43	1	QCEE
12	HV Cable Bracket	Adjustable by 100mm	1	QCEE
11	Jacking Pad	IP5XIP25	4	QCEE
10	Earthing Terminal	65x65X6 BS316L with tin	2	QCEE
9	Base Support	I-Beams	2	QCEE
8	Pressure relief Device	LPRD	1	Qualitrol
7	Label	BS316L	8	QCEE
6	Oil Filling Driftice	D60	1	QCEE
5	LV bushing	Porcelain 1kV/3150A	4	TianHua
4	Lift-Lug	WLL=4tons/unit D40	4	QCEE
3	Oil Level indicator	Magnetic type	1	Qualitrol or Moler
2	Temperature indicator	With contacts	1	Qualitrol or Moler
1	HV bushing	36kV 630A TypeC EN50180	3	KIVAG

CLP 中電
CONTRACTOR: QingDao Chongli Electrical Equipment Company


CONTRACT NO. 4600009234
PROJECT NO. 4501440386
DRAWN: WL DATE: 20221214
CHECKED: YJC APPROVED: LF
SCALE: SHEETS IN SET: 2/2

ASSET MANAGEMENT

TITLE: NATURAL ESTER(IFR3) IMMERSED DISTRIBUTION TRANSFORMER 2000KVA 11.3/0.39kV KNAN GENERAL LAYOUT

DRG. NO. TSD054210DCHR00101S
INFORMATION CLASS: PROPRIETARY

Note:
 (1) All dimensions are subject to 1% tolerance and weight are subject to 5% tolerance
 (2) Major components and equipments will be labelled clearly
 (3) The shape and position of major components and equipments may be changed in detailed design
 (4) The manufacture of components may be changed to other qualified one
 (5) HV cable box is facilitated with earth copper bar or strap
 (6) Rating plate is fixed onto a cooling-fin cover with stainless steel rivet or bolt
 (7) Transformer is equipped with 4 lift-lugs on cover that can lift the whole transformer without deformation
 (8) Alarm wiring through metallic is connected from pressure relief device, oil temperature indicator and oil level indicator to the alarm terminal box
 (9) M10 44-70 bolt and nut is used to fix cover and tank together, between them there is O-ring to seal, which is compatible to ester oil
 (10) HV and LV cable box have appropriate to hold the all the rated size cables
 (11) Painting color is RAL7033



CHPTL

中国大容量试验联盟（简称 CHPTL）是中国同类试验机构的唯一协作组织，隶属于中国电工技术学会。其主要目标是规范国家标准、行业标准及 IEC 标准在电力设备(交流 1000V 以上，直流 1200V 以上)型式试验中的协调应用。

China High Power Testing liaison (CHPTL) is the only organization in China which is formed to promote and coordinate the application of IEC/GB standard as well as industry standards in power electrical equipment type test (AC above 1000V, DC above 1200V). CHPTL is under the leadership and management of China Electro-technical Society.

CHPTL 成员单位如下：

The members of CHPTL are as follows:

西安高压电器研究院有限责任公司(XIHARI)

Xi'an High Voltage Apparatus Research Institute Co., Ltd. (XIHARI)

中国电力科学研究院(CEPRI)

China Electrical Power Research Institute (CEPRI)

辽宁高压电器产品质量检测有限公司(AQTC)

Liaoning High Voltage Apparatus Quality Test Co., Ltd. (AQTC)

沈阳变压器研究院有限公司变压器实验室(STRI)

Shenyang Transformer Institute Co., Ltd Transformer Laboratory (STRI)

上海电气输配电试验中心有限公司(SETC)

Shanghai Electric Power Transmission & Distribution Testing Center Co., Ltd. (SETC)

电力工业无功补偿成套装置质量检验测试中心(PRCIQTC)

Power Industry Reactive Compensation Equipment Quality Inspection & Test Center(PRCIQTC)

CHPTL 作为一个协作组织，本身并不出具型式试验报告。每一个 CHPTL 成员对其出具的型式试验报告的有效性和内容负责。

CHPTL as a collaboration does not itself issue test reports. Each CHPTL member issuing a test report is responsible for the validity and contents of that report.